

**Evaluation Report Nar-IS** October 18, 2023

Product Description: Glazed Wood Narrow Line Double or Single Door, Inswing, Impact

Manufacturer: Oliveri Millworks (OWW LLC), 3001 Tuxedo Ave., West Palm Beach, FL

**Statement of Compliance:** This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8<sup>th</sup> Edition (2023) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

## **Technical Documentation:**


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing Nar-IS, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports ESP013300P/-1 (signed/sealed by Ramesh Patel, P.E.) from Element Materials Technology, Wausau, WI, and TEL 03601908/03602027 (signed/sealed by William Shelton, P.E.), from Testing Evaluation Laboratories, Plant City, FL, with Testing Performed: TAS 201/202/203 1994
- 4) Supplemental Calculations to support Nar-IS, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document Nar-IS.

Limitations of Use: This product:

- May be used up to the sizes and configurations, with glazing with maximum sizes as shown in Nar-IS
- Achieves design pressures as shown in Nar-IS
- Is Large Missile Impact Resistant and does not require the use of shutters
- May be used in the High Velocity Hurricane Zone
- Requires Saflex CP (Storm) Interlayer with PET core per current Miami-Dade NOA or Kuraray Sentryglas per current Miami-Dade NOA, with lami as indicated in Nar-IS. I have evaluated these interlayer materials and find that they comply with the requirements of the 8<sup>th</sup> Ed. (2023) Florida Building Code for use in this product.
- Requires wood framing as indicated in Nar-IS

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Oliveri Millworks or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



10/18/2023 Lucas A. Turner, P.E. FL PE #58201